



Punjab Fire Services (Kharar)



FIRE SAFETY CERTIFICATE ਫਾਇਰ ਸੇਫਟੀ ਪ੍ਰਮਾਣ ਪੱਤਰ

NOC No **1503-68260-Fire/50035**

NOC Type: **Renew**

Dated **07-Apr-2023**

Certified that the **HENDERSON JUBILEE SCHOOL** at **HENDERSON JUBILEE SCHOOL, CIVIL HOSPITAL RAOD, NEAR BUS STAND, KHARAR DISTRICT MOHALI PIN CODE 140301** comprised of **0** basements and **2** (Upper floor) owned/occupied by **STERS** have complied with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **05-Apr-2023** in the presence of **Me stephan** (Name of the owner or his representative) and that the building / premises is fit for occupancy group **B** subdivision **B-1** (As per NBC) for period of **one year** from issue date. Subject to the following conditions.

Issued on **07-Apr-2023** at **Kharar**

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ **HENDERSON JUBILEE SCHOOL** ਜੋ ਕਿ **HENDERSON JUBILEE SCHOOL, CIVIL HOSPITAL RAOD, NEAR BUS STAND, KHARAR DISTRICT MOHALI PIN CODE 140301** ਸਮੇਤ **0** ਬੇਸਮੈਂਟ ਅਤੇ **2** (ਉਪਰਲੀ ਮੰਜ਼ਿਲ) ਮਲਕੀਅਤ/ਕਾਬਜ਼ਦਾਰ **STERS** ਨੂੰ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਪ੍ਰਭਾਵੀ ਅਤੇ ਬਚਾਅ ਦੇ ਰਾਸ਼ਟਰੀ ਬਿਲਡਿੰਗ ਕੋਡ ਅਨੁਸਾਰ ਜਿਸ ਨੂੰ ਸਬੰਧਤ ਅੱਗ ਬੁਝਾਉ ਅਧਿਕਾਰੀ ਵੱਲੋਂ ਪ੍ਰਮਾਣਿਤ ਕੀਤਾ ਗਿਆ **05-Apr-2023** ਮੌਜੂਦਗੀ ਵਿੱਚ **Me stephan** (ਮਾਲਕ ਦਾ ਨਾਮ ਜਾਂ ਉਸ ਦਾ ਪ੍ਰਤੀਨਿਧੀ) ਅਤੇ ਇਮਾਰਤ / ਬਿਲਡਿੰਗ ਆਬਾਦੀ ਲਈ ਯੋਗ ਹੈ। Occupancy Group **B** subdivision **B-1** (ਐਨ. ਬੀ. ਸੀ. ਦੇ ਅਨੁਸਾਰ) ਦੇ ਪ੍ਰਭਾਵੀ ਸਮੇਂ ਤੋਂ **ਇੱਕ ਸਾਲ** ਤੱਕ। ਜਿਸ ਲਈ ਨਿਮਨ ਅਨੁਸਾਰ ਹਦਾਇਤਾਂ ਹਨ।

ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ **07-Apr-2023** ਕਿੱਥੇ **Kharar** .

1. Fire Safety arrangements shall be kept in working condition at all the times.
ਹਰ ਸਮੇਂ ਅੱਗ ਤੋਂ ਬਚਾਅ ਦੇ ਯੰਤਰਾਂ ਨੂੰ ਚਾਲੂ /ਚੰਗੀ ਹਾਲਤ ਵਿੱਚ ਰੱਖਿਆ ਜਾਵੇ।
2. No, alteration/ addition/ change in use of occupancy is allowed.
ਕਿਸੇ ਵੀ ਤਰ੍ਹਾਂ ਦੇ ਬਦਲਾਅ/ ਵਾਧੇ/ ਕਾਬਜ਼ਕਾਰ ਵਿੱਚ ਬਦਲਾਵ ਦੀ ਮਨਾਹੀ ਹੈ।
3. Occupants/ owner should have trained staff to operate the operation of fire safety system provided there in.
ਉਪਲੱਬਧ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਯੰਤਰਾਂ ਦੀ ਵਰਤੋਂ ਤੋਂ ਰਹਿਣ ਵਾਲੇ ਲੋਕਾਂ / ਮਾਲਕਾਂ ਨੂੰ ਜਾਣੂ ਕਰਵਾਇਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ।
4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.
ਫਾਇਰ ਬ੍ਰਿਗੇਡ ਅਧਿਕਾਰੀ ਕਿਸੇ ਵੀ ਵਕਤ ਇਨ੍ਹਾਂ ਸਾਰੇ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਚੈੱਕ ਕਰ ਸਕਦਾ ਹੈ, ਜੇ ਕਰ ਕੋਈ ਕਮੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕਿਸੇ ਨੋਟਿਸ ਦੇ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਸਮਝਿਆ ਜਾਵੇਗਾ।
5. Occupants/ owner should apply for renewal of fire safety certificate one month prior to expiry of this certificate.

ਮਾਲਕ ਜਾਰੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਤੀ ਖਤਮ ਹੋਣ ਤੋਂ ਇੱਕ ਮਹੀਨਾ ਪਹਿਲਾਂ ਰੀਨੀਊ ਕਰਵਾਉਣ ਲਈ ਪਾਬੰਦ ਹੋਵੇਗਾ।

*** Above Details cannot be used as ownership proof.**

ਉਪਰੋਕਤ ਦਰਸਾਈ ਗਈ ਜਾਣਕਾਰੀ ਨੂੰ ਮਾਲਕਾਨਾ ਦੇ ਸਬੂਤ ਵਜੋਂ ਨਹੀਂ ਵਰਤਿਆ ਜਾਵੇਗਾ।

* This is digitaly created cerificate, no signatue are needed

ਇਹ ਡਿਜੀਟਲੀ (ਕੰਪਿਊਟਰਗਈਜ਼ਡ) ਤਿਆਰ ਕੀਤਾ ਗਿਆ ਸਰਟੀਫਿਕੇਟ ਹੈ, ਜਿਸ ਵਿੱਚ ਦਸਤਖਤ ਦੀ ਕੋਈ ਲੋੜ ਨਹੀਂ ਹੈ।

[Inspection Report by Fire Officer](#)


PERFORMA FOR INSPECTION REPORT REGARDING PREVENTION OF FIRE AND SAFETY MEASURES

(High rise/multistory buildings, hospitals, nursing homes, corporate offices, factories and hazardous storage)

Sr No	Details of the Building/premises	Date of inspection. <i>5/04/2023</i> Detail of the Building/premises/fire safety measures
1.	Name the building/premises (Location / Address)	HENDERSON JUBILEE SCHOOL, CIVIL HOSPITAL RAOD, NEAR BUS STAND, KHARAR DISTRICT MOHALI PIN CODE 140301
2.	Name And address of the owner	STERS, DIOCESE OF CHANDIGARH, MISSION COMPOUND, BROWN ROAD LUDHIANA
3.	Name and address of the occupier (s) with contact no.(s)	Same As Above
4.	Total area of the premises	11541Sq Mtr
5.	Total covered area	2651 Sq Mtr
6.	Height of the building from the ground level	07 Mtr
7.	Number of basements & its area	----
8.	Number of sanctioned floors	Ground+1 Floor
9.	Number of actual floors	Ground+1 Floor
10.	Parking area	Open Parking
11.	Detail of surrounding properties a) Left Side b) Right Side c) Front Side d) Back Side	
12.	Number of main gate with size	2 Number
13.	Number of fire extinguishers installed in the building on each floor with capacity, type with ISI marking number and date of manufacturing	ABC 8 Number CO2 6 Number Water Type 5 Number
14.	Detail of Hose reel on each floor Indicating size and length of rubber pipe	2 Number Each Floor
15.	Details of wet riser, No. of Landing valve, delivery hose, pipe and hose cabinet on each floor	----
16.	No of yard hydrant, with detail	----
17.	Whether basement is being used for parking, storage or office Has the basement sprinkler system? Give all details	----
18.	No. of manual fire alarms installed in the building	----

19.	Details of automatic fire detection system P.A system provided in the building	---
20.	Details of control panels	----
21.	Details of water storage capacity underground/overhead with size of tank.	Overhead 5000+5000 Ltr
22.	Detail of fire pumps with head and make a) Main pump b) Jockey Pump c) Diesel Pump	2 Number
23.	Position of fire service inlet 2way, 3way, 4way)	----
24.	No. of stair cases with size	3 Number
25.	No. of lifts and ramps with details of communication system	----

Owner's Checklist



Print

Print Certificate

**Please Download and keep the print of Inspection Report and Owner's Checklist also,
These documents should be produced on demand along with NOC**